REASONABLE POTENTIAL ASSESSMENT

Facility Name : South Bay Power Plant
NPDES Number : CA0001368

CAPWTT Session ID : 4
CAPWTT Session Name : s2
CAPWTT Session Date : 9/19/01

Pollutant : 1,1,1-Trichloroethane
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 1,1,2,2-Tetrachloroethane
ISWP Criteria : 11.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,1,2,2-Tetrachloroethane.

Pollutant : 1,1,2-Trichloroethane
ISWP Criteria : 42.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,1,2-Trichloroethane.

Pollutant : 1,1-Dichloroethane
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 1,1-Dichloroethylene
ISWP Criteria : 3.200 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 5 ug/l (nondetect)

REASONABLE POTENTIAL:

This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 1,1-Dichloroethylene

---

Pollutant : 1,2,4-Trichlorobenzene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 1,2-Dichlorobenzene
ISWP Criteria : 17000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,2-Dichlorobenzene.

Pollutant : 1,2-Dichloroethane
ISWP Criteria : 99.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,2-Dichloroethane.

Pollutant : 1,2-Dichloropropane
ISWP Criteria : 39.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,2-Dichloropropane.

Pollutant : 1,2-Diphenylhydrazine
ISWP Criteria : 0.540 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 500 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 500 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 1,2-Diphenylhydrazine

---

Pollutant : 1,2-Trans-Dichloroethylene
ISWP Criteria : 140000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,2-Trans-Dichloroethylene.

Pollutant : 1,3-Dichlorobenzene
ISWP Criteria : 2600.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,3-Dichlorobenzene.

Pollutant : 1,3-Dichloropropylene
ISWP Criteria : 1700.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,3-Dichloropropylene.

Pollutant : 1,4-Dichlorobenzene
ISWP Criteria : 2600.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 1,4-Dichlorobenzene.

Pollutant : 2,4,6-Trichlorophenol
ISWP Criteria : 6.500 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:

This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 2,4,6-Trichlorophenol

---

Pollutant : 2,4-Dichlorophenol
ISWP Criteria : 790.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2,4-Dichlorophenol.

Pollutant : 2,4-Dimethylphenol
ISWP Criteria : 2300.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2,4-Dimethylphenol.

Pollutant : 2,4-Dinitrophenol
ISWP Criteria : 14000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 100 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 100 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2,4-Dinitrophenol.

Pollutant : 2,4-Dinitrotoluene
ISWP Criteria : 9.100 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:

This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 2,4-Dinitrotoluene

---

Pollutant : 2,6-Dinitrotoluene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 2-Chloroethylvinyl Ether
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 2-Chloronaphthalene
ISWP Criteria : 4300.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2-Chloronaphthalene.

Pollutant : 2-Chlorophenol
ISWP Criteria : 400.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2-Chlorophenol.

Pollutant : 2-Methyl-4,6-Dinitrophenol
ISWP Criteria : 765.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 40 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 40 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for 2-Methyl-4,6-Dinitrophenol.

Pollutant : 2-Nitrophenol
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 3,3-Dichlorobenzidine
ISWP Criteria : 0.077 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 40 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 40 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 3,3-Dichlorobenzidine

---

Pollutant : 3-Methyl-4-Chlorophenol
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 4,4'-DDD
ISWP Criteria : 8.40000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 4,4'-DDD

Pollutant : 4,4'-DDE
ISWP Criteria : 5.90000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 4,4'-DDE

Pollutant : 4,4'-DDT
ISWP Criteria : 5.90000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.02 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.02 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for 4,4'-DDT

Pollutant : 4-Bromophenyl Phenyl Ether
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 4-Chlorophenyl Phenyl Ether
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : 4-Nitrophenol
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Acenaphthene
ISWP Criteria : 2700.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Acenaphthene.

Pollutant : Acenapthylene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Acrolein
ISWP Criteria : 780.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 50 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 50 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Acrolein.

Pollutant : Acrylonitrile
ISWP Criteria : 0.660 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 50 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 50 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Acrylonitrile

---

Pollutant : Aldrin
ISWP Criteria : 1.40000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.02 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.02 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Aldrin

---

Pollutant : alpha-BHC
ISWP Criteria : 0.013 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for alpha-BHC.

Pollutant : alpha-Endosulfan
ISWP Criteria : 0.009 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.05 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.05 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for alpha-Endosulfan

---

Pollutant : Anthracene
ISWP Criteria : 110000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Anthracene.

Pollutant : Antimony (Sb)
ISWP Criteria : 4300.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 1 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 1 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Antimony (Sb).

Pollutant : Arsenic (As-III)
ISWP Criteria : 36.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The MEC is set to the maximum detected value.

MEC = 5.5 ug/L (detect) and is LESS THAN the criterion requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The B is set to the maximum detected value.

B = 5.93 ug/l

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to decide whether to develop an effluent limitation for Arsenic (As-III).

Pollutant : Asbestos
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Benzene
ISWP Criteria : 71.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Benzene.

Pollutant : Benzidine
ISWP Criteria : 5.40000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 100 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 100 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Benzidine

---

Pollutant : Benzo (a) Anthracene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Benzo (a) Anthracene

---

Pollutant : Benzo (a) Pyrene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Benzo (a) Pyrene

---

Pollutant : Benzo (b) Fluoranthene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Benzo (b) Fluoranthene

---

Pollutant : Benzo (g,h,i) Perylene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Benzo (k) Fluoranthene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Benzo (k) Fluoranthene

---

Pollutant : Beryllium (Be)
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : beta-BHC
ISWP Criteria : 0.046 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.04 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.04 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for beta-BHC.

Pollutant : beta-Endosulfan
ISWP Criteria : 0.009 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for beta-Endosulfan

---

Pollutant : Bis (2-Chloroethoxy) Methane
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Bis (2-Chloroethyl) Ether
ISWP Criteria : 1.400 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Bis (2-Chloroethyl) Ether

---

Pollutant : Bis (2-Chloroisopropyl) Ether
ISWP Criteria : 170000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Bis (2-Chloroisopropyl) Ether.

Pollutant : Bis (2-Ethylhexyl) Phthalate
ISWP Criteria : 5.900 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 100 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 100 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Bis (2-Ethylhexyl) Phthalate

---

Pollutant : Bromoform
ISWP Criteria : 360.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Bromoform.

Pollutant : Butylbenzyl Phthalate
ISWP Criteria : 5200.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Butylbenzyl Phthalate.

Pollutant : Cadmium (Cd)
ISWP Criteria : 9.300 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 1 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 1 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Cadmium (Cd).

Pollutant : Carbon Tetrachloride
ISWP Criteria : 4.400 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 5 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Carbon Tetrachloride

---

Pollutant : Chlordane
ISWP Criteria : 5.90000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Chlordane

---

Pollutant : Chlorobenzene
ISWP Criteria : 21000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Chlorobenzene.

Pollutant : Chlorodibromomethane
ISWP Criteria : 34.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Chlorodibromomethane.

Pollutant : Chloroethane
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Chloroform
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Chrysene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Chrysene

---

Pollutant : Cyanide (CN)
ISWP Criteria : 1.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Cyanide (CN).

Pollutant : delta-BHC
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Di-n-Butyl Phthalate
ISWP Criteria : 12000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Di-n-Butyl Phthalate.

Pollutant : Di-n-Octyl Phthalate
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Dibenzo (a,h) Anthracene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Dibenzo (a,h) Anthracene

---

Pollutant : Dichlorobromomethane
ISWP Criteria : 46.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Dichlorobromomethane.

Pollutant : Dieldrin
ISWP Criteria : 1.40000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Dieldrin

---

Pollutant : Diethyl Phthalate

ISWP Criteria : 120000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Diethyl Phthalate.

Pollutant : Dimethyl Phthalate
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Endosulfan Sulfate
ISWP Criteria : 240.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.1 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.1 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Endosulfan Sulfate.

Pollutant : Endrin
ISWP Criteria : 0.002 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.05 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.05 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Endrin

---

Pollutant : Endrin Aldehyde
ISWP Criteria : 0.810 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.1 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.1 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Endrin Aldehyde.

Pollutant : Ethylbenzene
ISWP Criteria : 29000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Ethylbenzene.

Pollutant : Fluoranthene
ISWP Criteria : 370.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Fluoranthene.

Pollutant : Fluorene
ISWP Criteria : 14000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Fluorene.

Pollutant : gamma-BHC
ISWP Criteria : 0.063 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for gamma-BHC.

Pollutant : Heptachlor
ISWP Criteria : 2.10000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Heptachlor

---

Pollutant : Heptachlor Epoxide
ISWP Criteria : 1.10000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.01 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.01 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Heptachlor Epoxide

---

Pollutant : Hexachlorobenzene
ISWP Criteria : 7.70000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Hexachlorobenzene

---

Pollutant : Hexachlorobutadiene
ISWP Criteria : 50.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Hexachlorobutadiene.

Pollutant : Hexachlorocyclopentatadiene
ISWP Criteria : 17000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 40 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 40 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Hexachlorocyclopentatadiene.

Pollutant : Hexachloroethane
ISWP Criteria : 8.900 ug/l

WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Hexachloroethane

---

Pollutant : Indeno (1,2,3-cd) Pyrene
ISWP Criteria : 0.049 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Indeno (1,2,3-cd) Pyrene

---

Pollutant : Isophorone
ISWP Criteria : 600.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Isophorone.

Pollutant : Lead (Pb)
ISWP Criteria : 8.100 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The MEC is set to the maximum detected value.

MEC = 1.25 ug/L (detect) and is LESS THAN the criterion requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The B is set to the maximum detected value.

B = 1.02 ug/l

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to decide whether to develop an effluent limitation for Lead (Pb).

Pollutant : Mercury (Hg)
ISWP Criteria : 0.051 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 0.2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 0.2 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Mercury (Hg)

Pollutant : Methyl Bromide
ISWP Criteria : 4000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 5 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Methyl Bromide.

Pollutant : Methyl Chloride
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Methylene Chloride
ISWP Criteria : 1600.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 5 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Methylene Chloride.

Pollutant : N-Nitrosodi-n-Propylamine
ISWP Criteria : 1.400 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for N-Nitrosodi-n-Propylamine

---

Pollutant : N-Nitrosodimethylamine
ISWP Criteria : 8.100 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 20 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:

This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 20 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for N-Nitrosodimethylamine

---

Pollutant : N-Nitrosodiphenylamine
ISWP Criteria : 16.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for N-Nitrosodiphenylamine.

Pollutant : Napthalene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Nitrobenzene
ISWP Criteria : 1900.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 40 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 40 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Nitrobenzene.

Pollutant : PCBs
ISWP Criteria : 1.70000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2.5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2.5 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for PCBs

---

Pollutant : Pentachlorophenol
ISWP Criteria : 7.900 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 40 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 40 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Pentachlorophenol

---

Pollutant : Phenanthrene
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Phenol
ISWP Criteria : NA
WQBEL Required?: NO Criteria

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations.

Pollutant : Pyrene
ISWP Criteria : 11000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 10 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 10 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Pyrene.

Pollutant : Selenium (Se)
ISWP Criteria : 71.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The MEC is set to the maximum detected value.

MEC = 7.65 ug/L (detect) and is LESS THAN the criterion requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The B is set to the maximum detected value.

B = 8.02 ug/l

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to decide whether to develop an effluent limitation for Selenium (Se).

Pollutant : Silver (Ag)
ISWP Criteria : 1.900 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The MEC is set to the maximum detected value.

MEC = 1.48 ug/L (detect) and is LESS THAN the criterion requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was detected 1 times out of 1 observations. The B is set to the maximum detected value.

B = 1.54 ug/l

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to decide whether to develop an effluent limitation for Silver (Ag).

Pollutant : TCDD
ISWP Criteria : 1.40000E-08 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 8.84E-07 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 8.84E-07 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for TCDD

Pollutant : Tetrachloroethylene
ISWP Criteria : 8.850 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Tetrachloroethylene.

Pollutant : Thallium (Tl)
ISWP Criteria : 6.300 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 1 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 1 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Thallium (Tl).

Pollutant : Toluene
ISWP Criteria : 200000.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Toluene.

Pollutant : Toxaphene
ISWP Criteria : 2.00000E-04 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
This pollutant was not detected in either the effluent or the receiving water and both B and MEC are GREATER THAN the criterion.
Use BPJ to determine whether to develop an effluent limitation for Toxaphene

---

Pollutant : Trichloroethylene
ISWP Criteria : 81.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 2 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 2 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Trichloroethylene.

Pollutant : Vinyl Chloride
ISWP Criteria : 525.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 5 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 5 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Vinyl Chloride.

Pollutant : Zinc (Zn)
ISWP Criteria : 81.000 ug/l
WQBEL Required?: BPJ

EFFLUENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The MEC is set to the lowest detection limit.

MEC = 80 ug/L (nondetect) requiring analysis of ambient data.

AMBIENT DATA SUMMARY:
This pollutant was not detected in 1 observations. The B is set to the lowest detection limit.

B = 80 ug/l (nondetect)

REASONABLE POTENTIAL:
B is LESS THAN the criterion. Use BPJ to determine whether to develop an effluent limitation for Zinc (Zn).
